

## Culvert Work 2020

- |                               |  |
|-------------------------------|--|
| 1. Strolling Hills (Safeway)  | 18 inch has debris in it, pipe rusted and has collapsed in couple of areas and needs clean out and then rocks to divert water. |
| 2. Lariat & Strolling Hills:  | 18 inch needs regrading on North end   |
| 3. Lariat (near McNeil Rd)    | <b>Install Twin 30" Culverts Unit LS (may need traffic control one lane access on Lariat throughout construction)</b>          |
| 4. Lariat Loop                | At sign " <b>no trespass</b> " a 42 inch pipe needs regrading at west end  |
| 5. Flying C & Lariat          | 12 inch pipe needs regrading & placement of rocks on west end  |
| 6. Fallen Leaf near Flying C  | 24 inch pipe needs regrading on upper end and rock at discharge end to stop erosion  |
| 7. Fallen Leaf                | 12 inch pipe regrade upper end and add rocks   |
| 8. Fallen Leaf at 3041        | 12 inch pipe needs clean-out and asphalt at west end   |
| 9. Fallen Leaf                | 12 inch pipe collapsed needs replacing   |
| 10. Strolling Hills & FL      | 12 inch pipe needs regrading both ends and clean out--1/2 full debris  |
| 11. Strolling Hills before FL | 24 inch pipe needs regrading at east end and clean out   |
| 12. Ridge Pass                | 12 inch pipe at La Chenale needs regrading at both ends  |
| 13. Deer Creek at Flying C    | plugged culvert needs clean out  |